

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Nate Miller
 Address: Date Evaluated: 11-14-22
 Proposed Facility: SFA Design Flow (.1949): 360 Property Size:
 Location of Site: Property Recorded: Spring Other
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-3%	0-18	SL	FR GRANSP					PS
		18-42	SL	FR-SBLS.P	30" 32" 21"	7.54n	42n		.4
23	L-3-5%	0-20	SL	FR GRANSP					
		20-48	SL	FR-SBLS.P	36" 36" 21"	7.54n	48n		.4

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): PS
System Type(s)	25%	25%	Evaluated By: JZ
Site LTAR	.4	.4	Others Present:

