

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: 43824 Date Evaluated:
 Location of Site: Design Flow (.1949): 420 SQ Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS</u> <u>0-2</u>	<u>0-10</u>	<u>G SL</u>	<u>VFH NS/NR</u>					
		<u>10-36</u> ^H	<u>SBK SL</u>	<u>FR SS/SP</u>					<u>PS</u> <u>.4</u>
2		<u>0-9</u>	<u>G SL</u>	<u>VFH NS/NR</u>					
		<u>9-36</u> ^H	<u>SBK SL</u>	<u>FR SS/SP</u>					<u>PS</u> <u>.4</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>[Signature]</u> Others Present: <u>[Signature]</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<u>25% [Signature]</u>	<u>PS</u>	
Site LTAR	<u>.4</u>	<u>.4</u>	

