

Neville Engineering

919-740-3427

213 River Birch Lane
Chapel Hill, NC 27514

neveng@aol.com

January 6, 2023

Mr. Greg Pruitt
Pruitt Building Co.
Durham, NC

Re: Home for Amy and Daniel Pruitt
Holly Springs, NC


Dear Greg

This letter is to confirm that I have reviewed the structural drawings for the referenced project and have only one comment. The double 1 3/4" x 9 3/4" LLV spanning the 15' x 8' doors should be increased to 2- 1 3/4" x 11 3/4" LVL's or to 3- 1 3/4" x 9 3/4" LVL's.

My review concludes that, with this change, the drawings meet the structural requirements of the 2018 NC State Building Code.

Please contact me if you have questions.

Sincerely,



Augustus Neville, PE

