



# Permit Inspections Harnett County

**Permit Number: SFD2211-0027**

Description: **76x62 sfd 3 beds 3 baths**

Applied: **11/18/2022**

Approved: **9/20/2024**

Site Address: **721 RAMBEAUT RD**

Issued: **9/9/2024**

Finalized:

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **ISSUED**

Applicant: **MOORE CHARLES**

Parent Permit:

Owner: **MOORE CHARLES**

Parent Project:

Contractor: **MOORE CHARLES**

Details:

## LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOUNDATION SURVEY	CP Bucket		

Notes:

			T-POLE	James T Hall		eTRAKiT Inspection Request
--	--	--	--------	--------------	--	----------------------------

Notes:

10/11/2024 2:21 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

10/14/2024 1:39 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

			TEMP POWER CERTIFICATION	James T Hall		eTRAKiT Inspection Request
--	--	--	--------------------------	--------------	--	----------------------------

Notes:

10/11/2024 2:23 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com





# Permit Inspections Harnett County

10/14/2024 1:38 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

			SEWER CONNECTION	James T Hall		
--	--	--	------------------	--------------	--	--

Notes:

			WATER CONNECTION	James T Hall		
--	--	--	------------------	--------------	--	--

Notes:

			ROUGH IN	James T Hall		
--	--	--	----------	--------------	--	--

Notes:

			INSULATION	James T Hall		
--	--	--	------------	--------------	--	--

Notes:

			GAS PIPING	James T Hall		
--	--	--	------------	--------------	--	--

Notes:

	6/30/2023	7/12/2023	ADDRESS	GIS Bucket	APPROVED	
--	-----------	-----------	---------	------------	----------	--

Notes:  
 721 Rambeaut Rd  
 Spring Lake NC 28390

	9/11/2024	9/11/2024	FOOTING	James T Hall	DISAPPROVED	
--	-----------	-----------	---------	--------------	-------------	--

Notes:  
 Need continuous footing cross garage door opening clean loose dirt from footings

	9/12/2024	9/12/2024	FOOTING	James T Hall	APPROVED	eTRAKIT Inspection Request
--	-----------	-----------	---------	--------------	----------	----------------------------

Notes:  
 9/11/2024 1:07 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

	9/24/2024	9/24/2024	FOUNDATION	James T Hall	DISAPPROVED	
--	-----------	-----------	------------	--------------	-------------	--

Notes:  
 Expose all footings for inspection Missing anchor bolts in foundation walls per code Missing R 10 insulation on foundation wall per code or res check





# Permit Inspections Harnett County

	9/27/2024	9/27/2024	FOUNDATION	James T Hall	APPROVED	eTRAKIT Inspection Request
--	-----------	-----------	------------	--------------	----------	----------------------------

Notes:

9/24/2024 3:16 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

9/25/2024 2:13 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

	10/16/2024	10/16/2024	UNDER SLAB TRADES	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	----------------------	--------------	----------	----------------------------

Notes:

10/11/2024 2:20 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

10/14/2024 1:38 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

	10/21/2024	10/21/2024	SLAB	James T Hall	DISAPPROVED	eTRAKIT Inspection Request
--	------------	------------	------	--------------	-------------	----------------------------

Notes:

10/16/2024 8:44 AM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

10/17/2024 1:17 PM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com





# Permit Inspections Harnett County

10/18/2024 12:37 AM Charles Moore

Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

Need compaction letter for fill over 24"Missing lug footing for stairs behind back wall in garage

	10/23/2024	10/23/2024	SLAB	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	------	--------------	----------	----------------------------

Notes:  
 10/21/2024 2:24 PM Charles Moore  
 Contact Name: Charles Moore  
 Site Address: 721 RAMBEAUT RD  
 Phone: 9103337336  
 e-Mail: seymour1161@gmail.com

40			ENVIR OPERATIONS PERMIT	EH Bucket		
----	--	--	-------------------------------	-----------	--	--

Notes:

50			FINAL SFD STEMWALL**	James T Hall		
----	--	--	-------------------------	--------------	--	--

Notes:

