


4-Bedroom Septic Plan  
 Lot #79 – Duncan’s Crossing  
 Harnett County  
 Smith Douglas Homes

**DOUBLE BARRELL STREET**  
 50' R/W (PUBLIC & UTILITY ACCESS)



- \*House footprint to be field staked by surveyor and system verified prior to any construction
- \*\*Septic area must not be altered by construction activities.
- \*\*\*No cuts of 2' or greater within within 15' of septic area
- \*\*\*\* Recommend protective barrier around septic field during construction.

**BONNIE GIRL COURT**  
 50' R/W (PUBLIC & UTILITY ACCESS)  
 192.48'



25,088 SF  
 (0.58 AC)

\*If plumbing is not sufficient a pump tank will be required to septic field.

System: Gravity to serial dist.  
 Lines: Lines 3–6 (330')  
 0.4 LTAR  
 24" Max Trench Bottom  
 Accepted Status System  
 Repair: Pressure Manifold  
 Lines: Lines 1–3, 7–8 (370')  
 0.4 LTAR  
 24" Trench Bottom  
 Accepted Status System

GRAPHIC SCALE  
 1" = 50'



Adams  
 Soil Consulting  
 919-414-6761  
 Job #1146