



●	JUS414	USP	16	NA	16d/3-1/2"	16d/3-1/2"
●	MSH422	USP	13	Varies	10d/3"	10d/3"

Products						
PlotID	Length	Product	Plies	Net Qty	Fab Type	
DB1	7-0-0	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF	
FB1	17-0-0	1-3/4"x 14" LVL Kerto-S	3	3	FF	

Truss Placement Plan
SCALE: 3/8"=1'

▲ = Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS (BASED ON TABLES R502.5(1) & (2)) NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADERS/ROOF					
END REACTION (UP TO) 1000#	END REACTION (UP TO) 2500#	END REACTION (UP TO) 5100#	END REACTION (UP TO) 7650#	END REACTION (UP TO) 10200#	END REACTION (UP TO) 12750#
1700	2550	5100	7650	10200	12750
3400	5100	7650	10200	12750	15300
5100	7650	10200	12750	15300	
6800	10200	12750	15300		
8500	12750	15300			
10200	15300				
11900					
13600					
15300					

BUILDER	H&H Homes	COUNTY	
JOB NAME	Engage A&B Floor	ADDRESS	
PLAN	Engage A&B Floor	MODEL	2nd Floor
SEAL DATE		DATE REV.	
QUOTE #		DRAWN BY	Marshall Naylor
JOB #		SALESMAN	Marshall Naylor

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com
Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.
Signature: <u>Marshall Naylor</u>

comTECH
ROOF & FLOOR TRUSSES & BEAMS
Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444