Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 5465 Spring Hill Ch Rd ISSUED TO: Jones, Timothy & Carol LOT # REPAIR \square EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFD (58'x49') Proposed Wastewater System Type: Pump to 25% Red Sys Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: 6 Basement Yes X No May be required based on final location and elevations of facilities No Pump Required: XYes Type of Water Supply: Community Public Well Distance from well feet X Five years Permit valid for: No expiration Permit conditions: Date: 1/25/23 SEE ATTACHED SITE SKETCH Authorized State Agent:: REHS The issuance of this permit by the Health Department in no way guarantee the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Jones, Timothy & Carol PROPERTY LOCATION: 5465 Sprong Hill Ch Rd NOISIVIDAUS Facility Type: SFD (58'x49') Repair Expansion Basement? Yes Basement Fixtures? | Yes Pump to 25% Reduction System (Initial) Wastewater Flow: 360 Type of Wastewater System** (See note below, if applicable] Pump to 25% Reduction System (Repair) Number of trenches 4 Installation Requirements/Conditions Exact length of each trench 75 Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Soil Cover: 6 inches Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. _____ inches below pipe GPM Aggregate Depth: inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 1/25/23 Authorized State Agent: Construction Authorization Expiration Date: 1/25/28

Harnett County Department of Public Health Site Sketch

Property Location: 5465 Spring HIII C	hurch Rd	
Issued To: Jones, Timonthy & Carol	Subdivision	Lot #
Authorized State Agent:	REHS (OLIVER TOLKSOOF)	Date: 1/25/23
		/
	GAQA6E	/
		476
	state: Q	
	80	
	419	
	TI REPAIR,	
	DE WILL AVEN	
	180	
	WOODED	
	SPRING HILL CH. RD.	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.