

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: S BDRM Design Flow (.1949): 600 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS ^{cc} 2.5	0-12	G SL	VFD NS/NP					
		12" 12"	SBR SCL	FR S/SP	10/12 7/2				US
2	LS ^{cv/h} 2.5	0-22	G SL	VFD NS/NP					
		22-46	SBR SCL	FR SS/SP					PS .4
		46" ~50°/Rm							
3		0-18	G SL	VFD NS/NP					
		18-36	SBR SCL	FR SS/SP					PS .4
4	LS ^{cc}	0-14	G SL	VFD NS/NP					
		14" 14"	SBR SCL	FR S/SP	10/12 7/2 2/4"				US
5	cv/h	0-R 18-36"	G SL SBR SCL	VFD NS/NP FR SS/SP					PS .4
6		11							

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25% RGS		
Site LTAR	.4	.4	

