

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Date Evaluated:
 Address: Design Flow (.1949): 360 gpd Property Size:
 Proposed Facility: 3 BORN Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				.1944 Restr Horiz Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-20	G LS	VFB NS/NP					
		20-36"	SBK SCL	FB SS/NP					PS .5
2		0-20	G LS	VFB NS/NP					
		20-36"	SBK SCL	FB SS/NP					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OY Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25" x 4" RES		
Site LTAR	.5	.5	

