

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

August 17, 2023

Subject: 115 Ponchartrain Street  
Fuquay Varina, NC 27526  
Plan Revision Letter  
Harnett County Permit #: SFD2302-0011

Based on the request of the Contractor, 2 items on the plans will be revised. My assessment and recommendations are as follows:

- Item 1 – The double 2x10 front porch beam was changed to a triple 2x10. This beam change is acceptable.
- Item 2 – The double 2x10 beam in the porch ceiling to support the short rafters was changed to a double 2x8. This beam change is acceptable.

The 2 items noted above meet all the requirements of the 2018 North Carolina Building Code for Residences.



08 17 2023