



North Carolina State Laboratory of Public Health

Environmental Sciences

Inorganic Chemistry

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: James E Manhart III

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH

Robert Pope

307 CORNELIUS HARNETT BLVD

130 Kent Ln

LILLINGTON, NC 27546

Coats, NC 27521

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: **ES231101-0017**

Date Collected: 10/31/2023

Time Collected: 11:00

By: James Manhart III

Date Received: 11/01/2023

Time Received: 07:47

Sample Type:

Sampling Point: Well head

Well Permit No.

SFD2302-0033

Sample Source: New Well

Receipt Temp.: 4.0 °C

GPS Number:

Profile: New Well I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	0.002	0.010	mg/L	
Barium	0.248	2.0	mg/L	
Cadmium	<0.0005	0.005	mg/L	
Calcium	18		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	<0.01	1.3	mg/L	
Fluoride	0.169	4.00	mg/L	
Iron	<0.06	0.300	mg/L	
Lead	<0.003	0.015	mg/L	
Magnesium	7		mg/L	
Manganese	0.279	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
Nitrate	<1	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
pH	7.9		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	16.0		mg/L	
Sulfate	9.8	250	mg/L	
Total Alkalinity	93		mg/L	
Total Hardness	75		mg/L	
Zinc	0.19	5.0	mg/L	

Report Date: 11/14/2023

Reported By:

Marc Komlos



NC DEPARTMENT OF
HEALTH AND HUMAN SERVICES
Division of Public Health

Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

County: HAZLETT

Sample Name: Robert Pope

Sample ID #: ES231101-0017

Reviewer: Marc Komlos / James Marshall

TEST RESULTS AND USE RECOMMENDATIONS

1. Your well water meets federal drinking water standards for *inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*. You may have other water sampling results that are not taken into account in this report.

2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking unless you install a water treatment system to remove the checked substance(s). However, it may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.

<input type="checkbox"/> Arsenic	<input type="checkbox"/> Barium	<input type="checkbox"/> Cadmium	<input type="checkbox"/> Chromium	<input type="checkbox"/> Copper	<input type="checkbox"/> Fluoride	<input type="checkbox"/> Iron
<input type="checkbox"/> Lead	<input type="checkbox"/> Manganese	<input type="checkbox"/> Mercury	<input type="checkbox"/> Nickel	<input type="checkbox"/> Nitrate/Nitrite	<input type="checkbox"/> Selenium	<input type="checkbox"/> Silver
<input type="checkbox"/> Zinc						

3. While your lead levels do not exceed federal or state standards, the North Carolina Division of Public Health has concerns with any detection of lead. Should you have any questions please contact the NC Private Well and Health Program at (919) 707 - 5900.

4. Re-sample for lead and /or copper. Take a first draw and 30-second flush sample inside the house (preferably the kitchen sink) and a first draw and 4 minutes flush sample at the wellhead to determine the source of the lead and/ or copper.

5. The following substance(s) exceeded aesthetic drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

<input type="checkbox"/> Chloride	<input type="checkbox"/> Copper	<input type="checkbox"/> Fluoride	<input type="checkbox"/> Iron	<input type="checkbox"/> Manganese
<input type="checkbox"/> pH	<input type="checkbox"/> Silver	<input type="checkbox"/> Sulfate	<input type="checkbox"/> Zinc	

6. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium-restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.

b. Your sodium level exceeds 30 mg/L and may pose aesthetic issues such as bad taste, odor, staining of porcelain, etc.

7. Re-sampling is recommended in _____ months, to reinvestigate _____.