

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460


August 15, 2023

Subject: 387 Ballard Road  
Fuquay Varina, NC 27526  
Plan Revision Letter  
Harnett County Permit #: SFD2302-0043

Based on the request of the Contractor, 2 items on the plans will be revised. My assessment and recommendations are as follows:

- Item 1 - The 2x12 ceiling joists next to the stairs to the Bonus Room are attached to the 2x12 band joist with Simpson LS90 brackets. This attachment is acceptable.
- Item 2 – The stairs to the Bonus Room extended past the load bearing wall of the Garage into the floor framing. A double 2x12 will be added at the end of stairs and on each side of the stairs to support the double 2x12 of the stairs.

The 2 items noted above meet all the requirements of the 2018 North Carolina Building Code for Residences.



08 15 2023