

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

May 4, 2023

Subject: 387 Ballard Road  
Fuquay Varina, NC 27526  
Plan Revision Letter  
Harnett County Permit #: SFD2302-0043

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The 2 - #4 bars shown on the plans for the footings will not be installed. Removing the rebar from the footings is acceptable.

The footings without the rebar meet all the requirements of the 2018 North Carolina Building Code for Residences.

