



CIVIL AND STRUCTURAL ENGINEERING SERVICES, PLLC

SAMIR W. BAHHO, P.E.

Date: August 23, 2023

Red Rock Builders
1303 Olde Walker Mill Road,
Apex, North Carolina 27502

Reference: Framing : Lot 452, 105 Micahs Way,
Spring Lake, NC 28390

Woody,

Reference is made to Items 7 and 8 of Harnett County Inspector report dated 8/11/2023. This letter is to certify that the 2x10 header (bedroom 2) and the 2 2x8 headers on 2nd bathroom as shown on the approved plans and noted on the above-said inspection report **are not needed for stability of the structure** . The as-built framing of doors in bedroom 2 and bathroom 2 are stable and meet NCBC, Residential, 2018 load bearing requirement . **My seal and signature are affixed below for certification**

For any further questions please call me or email me. My telephone number is (919) 621-0628. My email address is ba.casespllc@gmail.com

Sincerely,

Samir W. Bahho, PE (License # 16941) Business License P-0537
Cc: Harnett County Inspection



August 23, 2023

