

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated:
 Proposed Facility: 3 B R m Design Flow (.1949): 360 Property Size:

Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1 | LS 0-2 | 0-12 | G SL | VFA NS/HR | | | | | |
| | | 12-40 | SBK CL | FO S/SP | | | | | PS .35 |
| 2 | | 0-16 | G SL | VFA NS/HR | | | | | |
| | | 16-40 | SBK CL | FO S/SP | | | | | PS .35 |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| | | | |
|-------------------------|----------------|---------------|--|
| Description | Initial System | Repair System | Other Factors (.1946): Site Classification (.1948): PJ Evaluated By: ex Others Present: - |
| Available Space (.1945) | ✓ | ✓ | |
| System Type(s) | 2506 | PDNGL | |
| Site LTAR | .35 | .35 | |

