



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

8/10/2023

**SUBJECT: SFD2303-0081**  
**SINGLE FAMILY DWELLING**

To: CUMBERLAND HOMES INC

Here are the results of all Inspections located at **196 INDIGO ST:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: GAS PIPING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: T-POLE  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks: not needed  
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: EH Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL SFD STEMWALL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: INSULATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 5/18/2023  
Completed Date/Time: 5/18/2023  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 5/17/2023 10:50 AM CUMBERLAND HOMES INC  
Please call me with any issues. Thank you, Dan (919)-616-2391  
Contact Name: CUMBERLAND HOMES INC  
Site Address: 196 INDIGO ST  
Phone: 9108924345  
e-Mail: NorrisBuildingGroup@yahoo.com

Inspection Type: FOUNDATION  
Scheduled Date/Time: 6/12/2023  
Completed Date/Time: 6/12/2023  
Inspector: James T Hall  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 6/7/2023 12:21 PM CUMBERLAND HOMES INC  
  
Contact Name: CUMBERLAND HOMES INC  
Site Address: 196 INDIGO ST  
Phone: 9108924345  
e-Mail: NorrisBuildingGroup@yahoo.com



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: UNDER SLAB TRADES  
Scheduled Date/Time: 6/28/2023  
Completed Date/Time: 6/28/2023  
Inspector: John B Kokoszka  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 6/26/2023 1:41 PM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC  
Site Address: 196 INDIGO ST  
Phone: 9108924345  
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspector BS changed the inspection assignment from BS to JBK

Inspection Type: SLAB  
Scheduled Date/Time: 6/30/2023  
Completed Date/Time: 6/30/2023  
Inspector: Daniel L Floyd  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 6/29/2023 7:35 AM CUMBERLAND HOMES INC  
Please call me with any issues. Thank you Dan (919)-616-2391  
Contact Name: CUMBERLAND HOMES INC  
Site Address: 196 INDIGO ST  
Phone: 9108924345  
e-Mail: NorrisBuildingGroup@yahoo.com

Inspection Type: ROUGH IN  
Scheduled Date/Time: 7/27/2023  
Completed Date/Time: 7/27/2023  
Inspector: Daniel L Floyd  
Result: CANCELLED  
Remarks: eTRAKiT Inspection Request  
Notes: 7/25/2023 8:19 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC  
Site Address: 196 INDIGO ST  
Phone: 9108924345  
e-Mail: NorrisBuildingGroupnc@gmail.com

Per contractors request.



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN SFD STEMWALL

Scheduled Date/Time: 8/10/2023

Completed Date/Time: 8/10/2023

Inspector: Daniel L Floyd

Result: DISAPPROVED

Remarks:

Notes:

Inspector DT changed the inspection assignment from DT to DLF

1. Loose anchor bolts through the garage and missing anchor bolt in garage on the front porch side Need an anchor bolt at garage personnel door 2. Missing nails in hurricane strap back corner of third garage 3. Seal around dryer duct 4. Missing nails plate on plumbing drain in the master bathroom 5. Missing nail plate on 14/2 switch wire by master bedroom door 6. Need an anchor bolt right side of front door 7. Seal hole in top plate at bathroom 8. Nails in hangers in the front bedroom are too short 9. Seal air barrier upstairs 10. Tape all vertical seams in house wrap Ok to insulate