Jason E Godwin, P.L.S.



Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

		PROJECT		
CLIENT:	CUMBERLAND HOMES		DATE:	6.27.23
PROJECT:	SOUTH CREEK S/D		CONTRACTOR:	D. PEEBLES
ADDRESS:	222 INDIGO ST		TECHNICIAN:	ВН
LOT #:	88			

TEST SUMMARY

PERFORMED NDT ON STEM WALL SOIL FILL MATERIAL AT SITE NOTED ABOVE USING A TARGET DENSITY OF 118PCF.
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

			TESTING F	RESULTS	
SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	99.20	117.1	122.3	4.0

RETURN VISIT REQUIRED

YES

TECHNICIAN:

NO 🗸

T / [2414 ...

SEAL DOSSIL

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.