

May 1<sup>st</sup>, 2023

B & B Restoration  
345 W Dora Street  
Angier, NC 27501

**RE: Existing Tank Application # SFD2304-0001**

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal, uncover D-Box. (\$25.00 fee incurred).**
- 2. Have system pumped out
- 3. Need site plan
- 4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

JEM/kh  
Copy - Central Permitting