



AA TAKLA ENGINEERING, PLLC Consulting. Design. Efficiency.

Atef A. Takla, PE | 919-358-1758 | ateftakla@taklaengr.com

NC Firm License No. P-1446
418 Vivaldi Dr. Durham, NC 27712



Project: Dale's Residence
Location: 103 Cypress Dr.
Spring Lake, NC
Date: 7/19/23
Company: Value Build
Care Of: paul

As requested A. Takla visited the site and observed the footings for the proposed house and found adequate w/ 2000 psf. Deep Trench (front right) was evaluated and we recommended that fabric (non-woven) be placed and backfill w/ # 57 stone.

Limitations of Inspection: Services provided are in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule and budget. The determinations contained in this report are based on conditions observed at the time of the evaluation. No guarantees or warranties, expressed or implied, under this Agreement or otherwise, shall be construed in connection with services provided. Sequencing, shoring, means and methods of construction are considered beyond the scope of this report.