NORTH CAROLINA ENERGY CODE COMPLIANCE CERTIFICATE*

(2018 NC Energy Code Section 401.3) Builder, Permit Holder, or Registered Design Professional **Building Air Leakage** Print Name: GC. ADAM Construction, INC ☑ Visually inspected according to 402.4.2.1 OR Signature: Building Air Leakage Test Results (Sec. 402.4.2.2) Property Address: ACH50 [Target: 5.0] or Date: CFM50/SFSA (Target: 0.30) Name of Tester/Company: Stepherson's insulation Rating - List the value covering largest R-Value area to all that apply Date: Ceiling/Roof: ____ R- 30-2-38 Ducts: Floor: Total-Duct Leakage Test Result (Sept. 403.2.2) Closed Crawl Space Wall: (CFM25 Total/100SF) [Target: 6] Closed Crawl Space:_____ Name of Tester/Company:___ Date: Phone: Basement Wall: Certificate to be displayed permanently. Fenestration: Door25: *A permanent certificate shall be posted on or in the electrical distribution panel, inside the kitchen cabinet or other approved location. List primary type when there is more than one value for each component (i.e. certificate shall list the value covering the largest area). Required testing shall be performed and reported by the permit holder, a NC licensed general contractor, a NC licensed HVAC contractor, a NC licensed HVAC contractor, a NC licensed Holder, a NC licensed design professional, a certified BPI Envelope Professional or a certified HERS rater. U-Factor: FULL GLASS. 26, 12 GLASS 21/WILDOW . 34

Solar Heat Gain Coefficient (SHGC): Full 64955 .

12 glass . 10 WIALOWS . 21