

т 919 773-1200 = F 919 773-9658

250 Shipwash Drive, Suite 104 = Garner = North Carolina = 27529

www.tyndallengineering.com

August 11, 2023

Ken Dawson Ken Dawson Homes, Inc. 2493 NC Hwy 242 North Benson, NC 27504

Email: kenndawson@hotmail.com

Reference: Engineering Services

6983 US-401

Fuquay-Varina, NC 27526 TE&D Project No.: 2301-020783

To Whom It May Concern;

As requested, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following items per the home inspection report:

- 1) Additional 2 x 4 vertical web installed to right end of B02 trusses between garage and front porch.
- 2) Analysis of LVLs used within structure.

The following conclusions and recommendations were noted:

- 1) We observed new 2 x 4 vertical webs had been installed to the B02 trusses between the garage and front porch due to the trusses being installed in the wrong orientation per the provided truss drawings. We observed the new webs had been fastened to the trusses with minimum 16" x 32" x 3/4" OSB gussets at both side of the trusses. Gussets were fastened at all intersecting members with (2) rows of nails at 3" o.c. Based on our observations and analysis, the existing configuration is adequate to support the anticipated loading conditions.
- 2) During our inspection, there were no structural drawings in regards to the first-floor wall/ceiling framing on-site; however, we observed LVLs were used at the following locations:
 - a. A (2) 1-3/4" x 9-1/4" LVL header at the middle-front bedroom supported by (2) 2 x 4 jacks and (2) 2 x 4 king studs at each end. Based on our observations and analysis, the current header is adequate to support the anticipated loading conditions.
 - b. A (2) 1-3/4" x 11-7/8" LVL header at the garage door supported by (3) 2 x 4 jacks at each end. Based on our observations and analysis, the current header is adequate to support the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely, Tyndall Engineering & Design

Tripp Amos PT III | 2301-020783 Prentice Tyndall Jr., P.E.



т 919 773-1200 = F 919 773-9658 250 Shipwash Drive, Suite 104 = Garner = North Carolina = 27529 www.tyndallengineering.com





Item 1)



т 919 773-1200 = F 919 773-9658 250 Shipwash Drive, Suite 104 = Garner = North Carolina = 27529 www.tyndallengineering.com



Item 2a)



Item 2b)