



October 18, 2023

C & C Services
Chad Tyndall
3782 Tyndall Bridge Road
Salemberg, NC 28385

Reference: Engineering Services
358 Hazelwood Road
Lillington, NC 27546
Project No.: 2301-020978

To Whom It May Concern;

As requested by the builder, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following items:

- 1) Observe the materials/condition of the foundation bearing soils post-construction.

The following conclusions and recommendations were noted:


- 1) Our inspection consisted of spot checking the soils at the bottom of the existing footing. The materials/conditions of the foundation bearing soils were visually observed, qualitatively probed and subjected to Static Cone Penetrometer (SCP) testing. Hand Auger Borings were advanced through the soils to the bottom of the footing. Based on our observations, analysis, and the results of our field-testing program, the in-situ soils were noted as being adequate to support the anticipated loading conditions (2000 PSF).

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Tripp Amos
PT III | 2301-020978

Prentice Tyndall Jr., P.E.





Site Inspected