



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: JAMES MANHART

HARNETT CO ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BLVD
LILLINGTON, NC 27546

Name of System:

Victor R. Bennett
7281 NC 42
Holly Springs, NC 27540

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: ES250401-0020

Date Collected: 03/31/2025

Time Collected: 11:00

By: James E. Manhart

Date Received: 04/01/2025

Time Received: 07:42

Sample Type: Raw

Sampling Point: Well head

Well Permit No. SFD 2305-0009

Sample Source: New Well

Receipt Temp.: 4.0 °C

GPS Number:

Profile: New Well I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.001	0.010	mg/L	
Barium	<0.1	2.0	mg/L	
Cadmium	<0.0005	0.005	mg/L	
Calcium	4		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	<0.01	1.3	mg/L	
Fluoride	<0.1	4.00	mg/L	
Iron	0.081	0.300	mg/L	
Lead	<0.003	0.015	mg/L	
Magnesium	<1		mg/L	
Manganese	0.017	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
Nitrate	<1	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
pH	6.5		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	5.6		mg/L	
Sulfate	<5	250	mg/L	
Total Alkalinity	20		mg/L	
Total Hardness	13		mg/L	
Zinc	0.42	5.0	mg/L	

Report Date: 04/11/2025

Reported By:

Marc Komlos



NC DEPARTMENT OF
HEALTH AND HUMAN SERVICES
Division of Public Health

Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

County: HARNETT

Sample Name: VICTOR R BENNETT

Sample ID #: SFD 2305-0009

Reviewer: MARC KOMLOS - JAMES E. MARSHALL ^{Am 2/24/5}

TEST RESULTS AND USE RECOMMENDATIONS

1. ☒ Your well water meets federal drinking water standards *for inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*. You may have other water sampling results that are not taken into account in this report.
2. ☐ The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking unless you install a water treatment system to remove the checked substance(s). However, it may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.

<input type="checkbox"/> Arsenic	<input type="checkbox"/> Barium	<input type="checkbox"/> Cadmium	<input type="checkbox"/> Chromium	<input type="checkbox"/> Copper	<input type="checkbox"/> Fluoride	<input type="checkbox"/> Iron
<input type="checkbox"/> Lead	<input type="checkbox"/> Manganese	<input type="checkbox"/> Mercury	<input type="checkbox"/> Nickel	<input type="checkbox"/> Nitrate/Nitrite	<input type="checkbox"/> Selenium	<input type="checkbox"/> Silver
<input type="checkbox"/> Zinc						
3. ☐ While your lead levels do not exceed federal or state standards, the North Carolina Division of Public Health has concerns with any detection of lead. Should you have any questions please contact the NC Private Well and Health Program at (919) 707 - 5900.
4. ☐ Re-sample for lead and /or copper. Take a first draw and 30-second flush sample inside the house (preferably the kitchen sink) and a first draw and 4 minutes flush sample at the wellhead to determine the source of the lead and/ or copper.
5. ☐ The following substance(s) exceeded aesthetic drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

<input type="checkbox"/> Chloride	<input type="checkbox"/> Copper	<input type="checkbox"/> Fluoride	<input type="checkbox"/> Iron	<input type="checkbox"/> Manganese
<input type="checkbox"/> pH	<input type="checkbox"/> Silver	<input type="checkbox"/> Sulfate	<input type="checkbox"/> Zinc	
6. ☐ a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium-restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.

☐ b. Your sodium level exceeds 30 mg/L and may pose aesthetic issues such as bad taste, odor, staining of porcelain, etc.
7. ☐ Re-sampling is recommended in _____ months, to reinvestigate _____.