

= HUS26 (Qty. 11)

▲= Denotes Left End of Truss (Reference Engineered Truss Drawing)

All Truss Reactions are Less than 3,000 lbs. Unless Noted Otherwise.

-- Denotes Reaction Greater than 3,000 lbs.

Reaction / # of Studs

## Truss Placement Plan SCALE: 1/4" = 1'-0"

	LOAD CHART FOR JACK STUDS										
	(BASED ON TABLES R502.5(1) & (b))										
	A END OF	•									
	END REACTION (UP TO)	REQ'D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER			
	1700	1		2550	1		3400	1			
	3400	2		5100	2		6800	2			
	5100	3		7650	3		10200	3			
	6800	4		10200	4		13600	4			
	8500	5		12750	5		17000	5			
	10200	6		15300	6						
	11900	7									
	13600	8									
	15200	_									

BUILDER	ILDER Weaver Development		CITY / CO. Sanford / Harnett		
JOB NAME	Lot 2-R West Preserve	ADDRESS	Thistle Court	<ul> <li>sheets for each truss design identified on th is responsible for temporary and permanent the overall structure. The design of the truss walls, and columns is the responsibility of the regarding bracing, consult BCSI-B1 and BCS</li> </ul>	
PLAN	Nicholson 3 Car (190717B)	MODEL	Roof	or online @ sbcindustry.com  Bearing reactions less than or equal to 3 prescriptive Code requirements. The cor ( derived from the prescriptive Code req foundation size and number of wood stu than 3000# but not greater than 15000#, be retained to design the support system	
SEAL DATE	Seal Date	DATE REV.	//		
QUOTE#		DRAWN BY	Christine Shivy	specified in the attached Tables. A regis retained to design the support system for	
JOB#	J0123-0223	SALES REP.	Lenny Norris	SignatureChri	

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables ( derived from the prescriptive Code requirements ) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Reilly Road Industrial Park rejistered design professional shall stem for any reaction that exceeds those gistered design professional shall be in for all reactions that exceed 15000#.

Fistive Shivy

Reilly Road Industrial Park Fayetteville, N.C. 28309

Phone: (910) 864-8787

Fax: (910) 864-4444

соттесн

ROOF & FLOOR TRUSSES & BEAMS