



TO: Halcyon Homes
P.O. Box 33578
Raleigh, NC 27636-3578

PROJECT #: 22-1674-B

PAGE: 1 of 1

DATE: September 8, 2023

LOCATION: Lot 32, Prince Place

PLANS REF: Lot 32, Prince Place by Murphy Garnow Design Group Project #: 22-1674

THE FOLLOWING CHANGE(S) OR PROPOSED CHANGE(S) LISTED BELOW ARE DEVIATIONS OR CLARIFICATIONS FOR THE ABOVE REFERENCED PLANS:

Porch Post Attachment: Page seven of the plans shows porch posts labeled as “4x4 treated post (or equal), see porch post notes”. Please be advised that the connectors listed in the “Porch Post Notes” are recommended connectors only. Alternative connectors that meet the NC Residential Code, any local codes, and/or the building inspector’s interpretation or approval may be substituted.

In closing, I trust that this letter fulfills your requirements at this time. Please do not hesitate to call if you have any further questions.

Sincerely,

Mark Minshew, P.E.
Southern Engineers, P.A.

