

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Thomas Aristida*
 Applicant: *Thomas Aristida*

Address: *1008 Joe Collins*

Proposed Facility: *SFD*

Location of Site:

Water Supply:

Evaluation Method: Auger Boring

Type of Wastewater:

- Public Individual Well Spring Other
 Sewage Industrial Process Mixed
 Pit Cut

Date Evaluated: *8-8-23*
 Design Flow (.1949): *720 GPD*

Property Size:

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1 | <i>L</i> | <i>0-17</i> | <i>LS</i> | <i>Fr/usp/usp</i> | <i>>48"</i> | <i>>48"</i> | <i>>48"</i> | <i>—</i> | <i>PS.4</i> |
| | | <i>17-48</i> | <i>SCI</i> | <i>Fi/sspl/sxp</i> | | | | | |
| | | <i>48-58</i> | <i>Sopp</i> | <i>Fi/sspl/sxp</i> | | | | | |
| 2 | <i>L</i> | <i>0-10</i> | <i>LS</i> | <i>Fr/usp/usp</i> | <i>>48"</i> | <i>>48"</i> | <i>>48"</i> | <i>—</i> | <i>PS.4</i> |
| | | <i>10-48</i> | <i>SCI</i> | <i>Fi/sspl/sxp</i> | | | | | |
| | | <i>48-57</i> | <i>Sopp</i> | <i>Fi/sspl/sxp</i> | | | | | |

| | | | |
|-------------------------|----------------|---------------|-----------------------------------|
| Description | Initial System | Repair System | Other Factors (.1946): |
| Available Space (.1945) | <i>✓</i> | <i>✓</i> | Site Classification (.1948): |
| System Type(s) | | | Evaluated By: <i>PS M.A. DEHS</i> |
| Site LTAR | <i>.4</i> | <i>.4</i> | Others Present: <i>A.T.</i> |

COMMENTS: _____

| LANDSCAPE POSITIONS | GROUP | TEXTURES | .1955 LTAR | CONSISTENCE MOIST | WET |
|---------------------|-------|---------------------|------------|--------------------|--------------------|
| R-RIDGE | I | S-SAND | 1.2 - 0.8 | VFR-VERY FRIABLE | NS-NON-STICKY |
| S-SHOULDER SLOPE | | LS-LOAMY SAND | | FR-FRIABLE | SS-SLIGHTY STICKY |
| L-LINEAR SLOPE | II | SL-SANDY LOAM | 0.8 - 0.6 | FI-FIRM | S-STICKY |
| FS-FOOT SLOPE | | L-LOAM | | VFI-VERY FIRM | VS-VERY STICKY |
| N-NOSE SLOPE | III | SI-SILT | 0.6 - 0.3 | EFI-EXTREMELY FIRM | NP-NON-PLASTIC |
| H-HEAD SLOPE | | SIL-SILT LOAM | | | SP-SLIGHTLY STICKY |
| CC-CONCLAVE SLOPE | | CL-CLAY LOAM | | | P-PLASTIC |
| CV-CONVEX SLOPE | | SCL-SANDY CLAY LOAM | | | VP-VERY PLASTIC |
| T-TERRACE | IV | SIC-SILTY CLAY | 0.4 - 0.1 | | |
| FP-FLOOD PLAN | | C-CLAY | | | |
| | | SC-SANDY CLAY | | | |

STRUCTURE

- SG-SINGLE GRAIN
- M- MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

