

Mark E. Jones, PE  
Structural Engineering and Design

March 27, 2024

NCT Specialty Contracting, Inc.  
70 Maple Brook Rd.  
Fuquay-Varina, NC 27526

Ref: Site Inspection and Analysis  
Attached Garage  
265 Hook Dr.  
Fuquay-Varina, NC  
Permit No. SFD2305-0108  
Project No. 24-054

To Whom it may concern;

The above referenced site was observed on March 25, 2024 to address the following condition(s):

1. No projection at the beginning of new wing wall.

Based on observations and analysis, the conclusions regarding the condition(s) are:

1. The end of the foundation wall at the garage door opening sits flush with the edge of the footing. As the garage door header shall be portal framed, the load bearing will be distributed inside the face of the wall/footing. The existing construction will adequately support all imposed loads. No action is required.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,



Mark E. Jones, PE

