

J.S. THOMPSON
ENGINEERING, INC

April 17, 2024

David Allgood
Davidson Home Crafters
5501 Erinvale Court
Holly Springs, NC 27540

Re: Americas Best House Plans – Amber

Dear Mr. Allgood:

The above noted plan for your residence under construction in Lillington, North Carolina was reviewed to address the lug footing noted by the inspector.

The short section of lug footing extending front to back from the left rear corner of the stairs to the end of the lug footing running left to right is not required with an omitted masonry fireplace. Framing was modified to eliminate loads on the wall from above. This configuration will provide the required support for all applied loads.

Please call me if you have any questions.

Sincerely,

J.S. Thompson Engineering, Inc.
N.C. License No. C-1733

Matthew G. Strother, P.E.

