



## **ROOF & FLOOR TRUSSES & BEAMS**

**Reilly Road Industrial Park** Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444

tearing reactions less than or equal to 3000# are eemed to comply with the prescriptive Code equirements. The contractor shall refer to the ttached Tables ( derived from the prescriptive Code equirements) to determine the minimum foundation ize and number of wood studs required to support eactions greater than 3000# but not greater than 5000#. A registered design professional shall be etained to design the support system for any eaction that exceeds those specified in the attached ables. A registered design professional shall be etained to design the support system for all eactions that exceed 15000#.

Bob Lewis

Bob Lewis

LOAD CHART FOR JACK STUDS (BASED ON TABLES R502.5(1) & (b))

SANFORD / LEE LONGLEAF Bob Lewis Bob Lewis - 2 SALES REP. DRAWN BY CITY / CO. ADDRESS

GREAT SOUTH BLDRS Seal Date Quote# JOB NAME SEAL DATE QUOTE ;

BUILDER THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com