DESIGN PROFESSIONAL INSPECTION FORM RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information

Residential Single-Family Project:   Code Enforcement Project:   N	
Code Enforcement Project:   Project Name: New Project No:	Commercial Project: Y D
Project Name: New Residential	Permit No: SFD 2306 - 0029
Project	Owner: MITCHELL C V41502A
Project Address: 1850 Shady Grove Rd	Suite No:
Date Inspected: Spring Lake, NC	
	Contractor Name: Signature Home Builders
Component Inspected: Footing, Foundation	n ·

Responsible Licensed NC Architect or NC Enginee

Name:	Architect of the Lingineer	1 1	199	 
	Scott G. Dowell, PE			
Firm Name:	OTG Consulting, PLLC			4.7
Phone Numbers:	Office: 336-414-1179	Mobile:	· ·	
Email Address:	otgconsulting37@gmail.cor		* *	
Mailing Address:	PO Box 1958, King, NC 2702	1,30,0	4	

APPLICABLE CODE: 2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: \*

Verified the dimensions met the approved plans. Soils met required bearing pressure of 2,000 psf. Foundation met requirements of NCRC 2018

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced

Code. Attach any additional documents if needed.

Scott G. Dowell, PE 037387

Licensed Architect or Engineer

## Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

12/2019

<sup>\*(</sup>subgrade form/letter may also be required)