

# Cruse And Associates, P.A.

*Engineering Services*



January 26, 2024

Robert Barefoot  
Barefoot Building Company  
P O Box 1411  
Coats, NC 27521

Re: 944 River Ridge Dr., Broadway, NC damaged foundation wall

This letter is meant to address the repair of the foundation wall damaged by a waste pipe penetration. The damaged section of the foundation wall should be removed down to the footing and re-built up to original height. Provide a lintel over the pipe sleeve and anchor bolts as required.

Thank you. Please contact me if I can be of further assistance or if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Randy L. Cruse', written in a cursive style.

Randy L. Cruse, PE

