

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

November 14, 2023

Subject: 285 Deer Trail Lane  
Fuquay Varina, NC 27526  
Framing Inspection Letter  
Harnett County Permit #: SFD2307-0068

Based on the request of the Contractor, I looked at 1 item from the framing inspection for code compliance. My assessment and recommendations are as follows:

Item 1 – There is a 2x12 ridge beam noted on the left end of the roof plan. The Contractor used a 2x10 ridge with a 2x4 attached at the bottom. This revised 2x10 ridge beam with a 2x4 bottom extension is acceptable.

The 1 item noted above meet all the requirements of the 2018 North Carolina Building Code for Residences.



11 14 2023