

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Michael Krasuski PROPERTY LOCATION: 20 Warner Hill Crt. Fuquay Varina
 SUBDIVISION _____ LOT # 1

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: SFD 50' x ~~60~~ 65'

Proposed Wastewater System Type: _____

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years No expiration

Permit conditions: _____

Authorized State Agent: James E. Marshall JR. REHS Date: 8-14-23 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Michael Krasuski PROPERTY LOCATION: 20 Warner Hill Crt. Fuquay Varina
 SUBDIVISION _____ LOT # 1

Facility Type: SFD 50' x ~~60~~ 65' New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 50% Reduction System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable)

50% Reduction (Repair)

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>4</u>	Trench Spacing: <u>7</u> Feet on Center
Pump Tank Size <u>1000</u> gallons	Exact length of each trench <u>50</u> feet	Soil Cover: <u>6</u> inches
	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>22-18</u> inches (Trench bottoms shall be level to +/-1/4" in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe 2 inches above pipe 12 inches total

Conditions: A 25%/50% Repair may fit BUT WILL BE Extremely Tight

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

***If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Marshall JR. REHS Date: 8-14-23
 Construction Authorization Expiration Date: 8-14-28

SR, 1447


Application # SFD 2307-0079

Harnett County Department of Public Health Site Sketch

Property Location: 20 Warner Hill Ct. Fuquay Varina, 27526

Issued To: Michael Krasuski Subdivision _____ Lot # 1

Authorized State Agent: James E. [Signature] ~~REAR~~ Date: 8-14-23



Warner Hill Ct.

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.