

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

October 6<sup>th</sup>, 2023

Tanya Adams  
159 Camila Rd  
~~Raleigh, NC 27606~~  
Angier 27501

**RE: Existing Tank Application # SFD2307-0082**

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal, uncover D-Box. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Replace Sanitary Tee with filter. Mark House Box.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

JEM/kh  
Copy - Central Permitting