

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

July 1, 2024

Subject: 32 Dauphine Street
Fuquay Varina, NC 27526
Plan Revision Letter #2
Harnett County Permit #: SFD2308-0046

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- Item 1 – The support beams in the crawlspace were specified as 2-2x12 members in the plans. The Contractor would like to use a triple 2x10 beam in lieu of the double 2x12 beam. This beam substitution is acceptable.

The 1 item noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.



07 01 2024 EDT