

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460


November 15, 2023

Subject: 32 Dauphine Street
Fuquay Varina, NC 27526
Plan Revision Letter
Harnett County Permit #: SFD2308-0046

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- Item 1 – The continuous footings for this project will be modified. The new continuous footings will be 20”x 10” with 2 - #4 bars continuous. All other footings shown in the plans will remain the same.

The 1 item noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.



11 15 2023