

Harnett County Department of Public Health

PERMIT # SFD2308-0048

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 501412 Church Left of RD

Name: (owner) Davidson Homes SUBDIVISION Prince Place LOT # 37

System Installer: Quality Septic

Basement with plumbing: Garage Number of Bedrooms 4

Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: 25% Retention System Type B6 Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

EZ Flow


This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

2-14-24 - Foundation Details

RUN ACROSS SYSTEM -
Had Super CUT
DRAINS AT FOUNDATION
Left Pipe in place
that runs across the
DRAIN LINES.
Wanted super treat
this still could cause
A WEAK POINT IN
System and cause
Failure before
signing off.

* Accepted status
per PCD
ARLHA.

* NEEDS DRAIN FIXED
for final.



* Foundation DETAILS
to be Renoted
AS TOLD TO GC.
ON JOB
AT INSPECTION

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

_____ D-Box _____ Pump _____ Alarm _____ H2O Line _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% Retention Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 1 of each ditch 405 feet ditches 3 feet ditches 20" inches
 French Drain Required: _____ Linear feet

Authorized State Agent James E. Marden Date 2-14-24