



FOUNDATION PLAN
FOR REFERENCE ONLY

Inspections were performed on 10/20/2023 for the following items:

- 1) Masonry foundation wall and masonry piers
 - a) The masonry foundation wall is of specified thickness, its top course is grouted solid, has proper footing projection and meets or exceeds requirements of ETA project no. 23-26-091.
 - b) The correct number of masonry piers are installed, the masonry piers meet or exceed the specified dimensions, their top course is grouted solid, the piers have proper footing projection, and meets or exceeds requirements of ETA project no. 23-26-091.

Note:
Inspection does not include verification of termite treatment if required, crawl space ventilation, ground clearances, drainage and waterproofing, and a debris free and level crawl space.

Local governing municipality to provide clearance to proceed with backfilling and framing.

Engineering Tech
ASSOCIATES, P.A.
STRUCTURAL ENGINEERS
License No. C-3870
318 W Millbrook Rd. Unit 201
Raleigh, North Carolina 27609
Phone (919) 844-1661

VALUE BUILD HOMES	
SCOPE	FOUNDATION INSPECTION
LOC	19673 NC 27 CAMERON, NC
REV #	REF PROJ #
DATE	

ENG: TRB
DATE: 10/20/2023

PARENT
23-26-091

PROJECT NO.
23-77-330

SHEET NO.
SL1
1 of 1