PROJECT: Atherstone REPORT DATE: 5/13/2024

LOCATION: Angier, NC COMMENTS:

CONTRACTOR: LGI

STREET ADDRESS: 316 lvy Bank LOT NO: 111

PERMIT NO.: SFD2308-0065 COMPONENT: 3rd Party Mono Slab

Summaries of Engineering Services performed, including Field Test Data. Location, Elevations and Depths are estimated.

SUMMARY:

Arrived on site as requested by the contractor to perform a third party inspection of a turn down slab at the above referenced residential site. The design bearing capacity is 2000 psf. Footing and slab areas were probed and found capable of supporting an allowable soil bearing capacity of 2000psf. Footings are free of loose dirt and cleared of any organic material. Footings were a minimum of 16" wide and 20" deep. All footing depths extend beyond the 12" frost line depth. Slab has been filled with suitable soil and compacted. Slab thickness measured a minimum of 4". All thickened slab locations were installed per the architectural foundation plan. Contractor has installed a 6 mil. vapor barrier over slab. Contractor has installed a 2" - R-10 insulation board around the perimeter of the exterior footing. This work was performed in accordance with accepted engineering practices as required by the 2018 North Carolina Residential Building Code. These areas were approved for the placement of 3000 psi concrete.



APPENDIX G

Design Professional Inspection Form

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single Family Project: x Y N Commercial Project Y N					
Code Enforcement Project No:			Permit #: SFD2308-0065		
Project Name:	Atherstone		Owner:		
Project Address: 316 lvy Bank		Suite No:			
Date Inspected: 5/13/24			Contractor Nam LGI		
Component Inspected 3rd Party Mono Slab					

Responsible Licensed NC Architect or NC Engineer

Name:	Brandon M. Holt, P.E.		
Firm Name:	ET Engineering		
Phone Numbers:	Office:	Mobile: (336)	
Email Address:	Bmholt75@outlook.com		

Describe Element/Cor	nponent/Type of Inspection:*	3rd Party Mono Slab	
2018 NCBC = 2018 NC	building Code: 2018 NCRC = 20)18 NC Residential Code	
APPLICABLE CODE:	2018 NCRC		

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

Licensed Architect or Engineer

Inspection Department Disclaimer:

Upon the receipt of a signed written document as required by G.S. 160D-11-6, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in the common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

^{*(}subgrade form/letter may also be required)