



●	HUS410	USP	24	NA	16d/3-1/2"	16d/3-1/2"
---	--------	-----	----	----	------------	------------

Products						
PlotID	Length	Product	Plies	Net Qty	Fab Type	
DB1	5-0-0	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF	
FB1	16-0-0	1-3/4"x 14" LVL Kerto-S	3	3	FF	
FB2	9-0-0	1-3/4"x 14" LVL Kerto-S	2	2	FF	
GDH	14-0-0	2x12 SP No.2	3	3	FF	

▲ = Indicates Left End of Truss  
(Reference Engineered Truss Drawing)  
Do NOT Erect Truss Backwards

**Truss Placement Plan**  
SCALE: 1/4"=1'

LOAD CHART FOR JACK STUDS (BASED ON TABLES B502.5(1) & (2)) NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADERS/ROOF		
END REACTION (UP TO) @ END OF HEADERS	END REACTION (UP TO) @ END OF HEADERS	END REACTION (UP TO) @ END OF HEADERS
1700	2550	3400
3400	5100	6800
5100	7650	10200
6800	10200	13600
8500	12750	17000
10200	15300	
11900		
13600		
15300		

<b>BUILDER</b>	A & G Residential	<b>CITY / CO.</b>	Coats / Harnett
<b>JOB NAME</b>	Lot 8 Turlington Acres	<b>ADDRESS</b>	Regis Lane
<b>PLAN</b>	Hampton 2nd Floor	<b>MODEL</b>	Floor Trusses
<b>SEAL DATE</b>	3/12/20	<b>DATE REV.</b>	08/22/23
<b>QUOTE #</b>		<b>DRAWN BY</b>	Marshall Naylor
<b>JOB #</b>	J0823-4518	<b>SALES REP.</b>	Marshall Naylor

**THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.**  
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSH-B1 and BCSH-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Marshall Naylor  
Marshall Naylor

**comtech**  
ROOF & FLOOR  
TRUSSES & BEAMS

Reilly Road Industrial Park  
Fayetteville, N.C. 28309  
Phone: (910) 864-8787  
Fax: (910) 864-4444