Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an improvement Permit
ISSUED TO: Southern Tide Homes Subdivision Cotton Frans Lot # 31
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
NEW REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFD 55' X 50
Proposed Wastewater System Type: 25% NEDVOTUN
Projected Daily Flow: 420 GPD
Number of bedrooms:
Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from wellfeet Permit valid for: Five years
Permit conditions: No expiration
1-7 7048
Authorized State Agent: Date: 5-22-23 SEE ATTACHED SITE SKETCH
Authorized State Agent: Date: 5 - 22 - SEE ATTACHED SITE SKETCH The issuance of this permit by the dealth Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
ISSUED TO: Southern Tide Homes PROPERTY LOCATION: 276 Deer Tail LN, Fugury Var. SUBDIVISION COTTON FARMS LOT # 31
SUBDIVISION COTTON FARMS LOT # 31
Facility Type: SFV 33 1 92 New Expansion Repair
Racomant? Yes Py No. Racomant Fixtures? Yes 146
Type of Wastewater System** 25% RSDUE WW System (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable)
50% Repair)
Installation Requirements/Conditions Number of trenches 3
Septic Tank Size 1000 gallons Exact length of each trench 120 feet Trench Spacing: Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 20 > 18 inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $\pm 1/4$ " 36" above the trench bottom)
Another sea traditional contract to the set of the set
in all directions) Pump Requirements: ft. TDH vsGPM
Aggregate Depth: inches above pip
Conditions: inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE JOST FROM ANY RADT OF SERVIC SYSTEM OR REPAIR AREA
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
Owner/Legal Representative Signature: Date:
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
5 M I Am
Authorized State Agent: ames [Manhan Date: 9-22-23
Authorized State Agent: Date: $9-22-23$ Construction Authorization Expiration Date: $9-22-28$
Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

Property Location: 226 Peer Tail Ln, Fugury Varing, 27526

Issued To: Southern Tide Homes Subdivision Cotton Farms Lot# 31

Authorized State Agent: Manhan Fix 12843

Date: 9-22-23

