


184  
 4-Bedroom Septic Plan  
 Lot #37 - Duncan's Crossing  
 Harnett County  
 Smith Douglas Homes

- \*House footprint to be field staked by surveyor and system verified prior to any construction
- \*\*Septic area must not be altered by
- \*\*\*No cuts of 2' or greater within
- \*\*\*\* Recommend protective barrier around septic field during construction.

279.99'



37

33,210 SF  
 (0.76 AC)

\*If plumbing is not sufficient a pump tank will be required to septic field.

System: Gravity to serial dist.  
 Lines: Lines 1-3 (350')  
 0.35 LTAR  
 18" Max Trench Bottom  
 Accepted Status System  
 Repair: Pressure Manifold  
 Lines: Lines 1-4 (300')  
 0.35 LTAR  
 18" Trench Bottom  
 T&J Panel 50% reduction

**DECOY SPREAD**  
 50' R/W (PUBLIC  
 & UTILITY ACCESS)

GRAPHIC SCALE  
 1" = 50'



Adams  
 Soil Consulting  
 919-414-6761  
 Job #1146