Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #:

Code:

☐ Mixed

## SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Sewage

Type of Wastewater:

Owner: Applicant:
Address: 184 Delos spleab pl.
Proposed Facility: 5FD
Location of Site:
Water Supplier Date Evaluated: 9/18/23
Design Flow (.1949): 480 61°()
Property Recorded: Property Size: Water Supply: ☐ Well ☐ Spring ☐ Public☐ Individual Other Evaluation Method: Auger Boring ☑ Pit ☐ Cut

☐ Industrial Process

P R O F I	.1940 Landscape Position/ Slope %	Horizon Depth (ln.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
L E #			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
pst)	L.ss	0-19	GHISL	VF/nS/rp/Sen		76	_	_	1.5.
	2-5%	14-36	SBK/SC	VF/25/20/5020 F;/55/20/6020 F-/55/1020	_	36	@36	-	0.4
		16-48	Sup	Fr/sploxp					
			_						

Description	Initial System,	Repair System		
Available Space (.1945)		V,		
System Type(s)	V			
Site LTAR	0.4	0.4		

Other Factors (.1946):

Site Classification (.1948): P.S.
Evaluated By: MAREHS

Others Present: AT

COMMENTS: \_\_\_\_

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY C-CLAY

0.4 - 0.1


STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB GR-GRANULAR MINERALOGY SLIGHTLY EXPANSIVE

SC-SANDY CLAY

**EXPANSIVE** 

SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY

PL-PLATY PR-PRISMATIC



Deloy Sphead PL.