Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: \(\sigma \) This He Ct.

Date Evaluated: \(\lambda - \lambda - \lambda \) Proposed Facility: \(\sigma \) Design Flow (.1949): \(\sigma \) GPD Property Size:

Location of Site:

Water Supply:

Water Supply:

Water Supply:

Auger Boring

Pit

Cut

Type of Wastewater:

Sewage

Industrial Process

Mixed

P R O F I	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
L E #			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	L.SS. 5%	0-18	waysL	V ft, NS, NP, Sex	-	-	_	_	/°S.
		18-48	SBK/SC	Fi, SS, MP, Sexp	10 /R 6/2 Z364	48"	_	_	0.4
2	Li 83,	0-20	mby/SL	VFr, ns, ny, Jeny	_		ſ		<i>ps.</i>
		20-48	SBIZSC	Fi, SS, NH, Sex	10 YR 6/1 = 38°	48"		_	0.4
3							_	_	/°S.
		18-48	SISIE/SC	Fi, SS, Ay Sext	10 YR 6/1 = 3/	48"	-	-	0.4
					19				

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948): PSA MREH
Available Space (.1945)	1	8/	Evaluated By:
System Type(s)	6		Others Present: AT.
Site LTAR	0.4	0.4	a sessential and a full ass

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VED VEDV EDIADI E	NE NON STICKY
S-SHOULDER SLOPE L-LINEAR SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE	П	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM	S-STICKY VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE	III	SI-SILT SIL-SILT LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			

IV SIC-SILTY CLAY C-CLAY

0.4 - 0.1

SC-SANDY CLAY

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

ABK-ANGULAR BLOCKY PL-PLATY

Thistle Court