

**Adams Soil Consulting
1676 Mitchell Road
Angier, NC 27501
919-414-6761**

June 27, 2024
Project #1868

This document is submitted in addition to the "Notice of Intent to Construct" submittal package previously supplied to the local health department in pursuant to G.S. 130A-336.1

RE: 1516NC 55W - Coats, NC -- (Harnett County, NC) (PIN# 0691-53-6093)

To whom it may concern:

This letter is to notify the Harnett County Environmental Health Department that the construction of the wastewater system has been completed. The system was installed to acceptable construction standards. The installation was constructed in conformance to the original construction documents. This document may serve as "Authorization to Operate" the installed system.

Operation and Management Program

Have the effluent filter in the septic tank cleaned periodically by a professional. Have the solids pumped out of the septic tank every 3-5 years by a professional. Maintain adequate vegetative cover over the drainfield. Keep surface waters away from the tank and drainfield. Do not pour grease or oil down the sink. Contact a professional for periodic maintenance.



Alex Adams
Adams Soils Consulting, PLLC
NC Licensed Soil Scientist #1247

OWNER ACCEPTANCE OF SEPTIC SYSTEM

I, Joshua Jones, owner of 1516 NC 55 W, Coats, accept the septic
Print Name

system installed at my property as designed by Adams Soil Consulting, PLLC and installed by Gene's Backhoe Service.

Joshua Jones
Owner Signature

7/9/24
Date