



NC Truss Design and Manufacturing

3/27/2024

To: Joshua Sain

From: Builders FirstSource Truss Department

Subject: DR Horton Lot 40 McKay

Mr. Sain,

We were asked to review the roof truss installation at this project and I did so on 3/26/2024.

The installation team switched the positions of two trusses, an A09 and an A12. Fortunately, the design of these two trusses uses exactly the same lumber and plates and the trusses are identical in their manufacture. The only theoretical difference is the interior bearing but the actual sealed designs are the same and because of this they are interchangeable in the installation.

Having reviewed all of the drawings and the installation, we are satisfied that this assembly will perform within code and within all of our original design parameters. Please feel free to contact me on this or any other truss project.

Sincerely,

Chuck Rogers



**Chuck Rogers**

**Trussman**

Central North Carolina

[Chuck.Rogers@BLDR.com](mailto:Chuck.Rogers@BLDR.com)

C: 919.370.0922 | BLDR.com

**OUTPERFORM TODAY. TRANSFORM TOMORROW.**