

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547  
fax: 910-893-9371

October 16, 2023

Steve Thomas  
PO Box 875  
Broadway, NC 27505

**Re: Status of Improvement Permit Application #SFD2309-0088**

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to accurately mark property lines and ALL irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark ALL house and building corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. **Property needs brush, trees and vegetation removed from septic area and the house location**
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other-

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS  
Environmental Health Specialist  
Harnett County Department of Public Health

MO/KH  
Copy: Central Permitting