

## Harnett County 420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

5/21/2024

SUBJECT: **SFD2309-0088** 

SINGLE FAMILY DWELLING

To: THOMAS CLIFFORD STEVE JR

Here are the results of all Inspections located at 12583 MCDOUGALD RD:

Inspection Type: GAS PIPING

Scheduled Date/Time: Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes:

Inspection Type: INSULATION

Scheduled Date/Time: Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes:

Inspection Type: SEWER CONNECTION

Scheduled Date/Time: Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes:

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time: Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes:



## **Harnett County**

420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone: Fax:

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: Completed Date/Time:

Inspector: EH Bucket

Result: Remarks: Notes:

Inspection Type: FINAL SFD STEMWALL\*\*

Scheduled Date/Time: Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 2/13/2024
Completed Date/Time: 2/14/2024
Inspector: GIS Bucket
Result: APPROVED

Remarks:

Notes: 12583 MCDOUGALD RD BROADWAY 27505.

10/2/2023 11:30:45 AM

Inspection Type: FOOTING
Scheduled Date/Time: 2/14/2024
Completed Date/Time: 2/14/2024
Inspector: Steven Gazlay
Result: APPROVED

Remarks: Notes:

Inspection Type: T-POLE
Scheduled Date/Time: 2/22/2024
Completed Date/Time: 2/22/2024
Inspector: Steven Gazlay
Result: APPROVED

Remarks: Notes:



## **Harnett County**

420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone: Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 2/22/2024
Completed Date/Time: 2/22/2024
Inspector: Steven Gazlay
Result: DISAPPROVED

Remarks:

Notes:

Missing R-10 insulation. Remove organic debris and broken block from fill areas. Need address

numbers posted onsite.

Inspection Type: FOUNDATION
Scheduled Date/Time: 2/26/2024
Completed Date/Time: 2/26/2024
Inspector: John B Kokoszka
Result: APPROVED

Remarks: Notes:

Inspection Type: UNDER SLAB TRADES

Scheduled Date/Time: 3/8/2024 Completed Date/Time: 3/8/2024

Inspector: John B Kokoszka Result: DISAPPROVED

Remarks:

Notes:

Missing sleeves at lug footing

Inspection Type: UNDER SLAB TRADES

Scheduled Date/Time: 3/12/2024
Completed Date/Time: 3/12/2024
Inspector: John B Kokoszka
Result: APPROVED

Remarks: Notes:

Inspection Type: WATER CONNECTION

Scheduled Date/Time: 3/12/2024 Completed Date/Time: 3/12/2024 Inspector: John B Kokoszka Result: APPROVED

Remarks: Notes:



## Harnett County 420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone: Fax:

Inspection Type: SLAB
Scheduled Date/Time: 3/15/2024
Completed Date/Time: 3/15/2024
Inspector: John B Kokoszka
Result: APPROVED

Remarks: Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 5/14/2024
Completed Date/Time: 5/14/2024
Inspector: James T Hall
Result: DISAPPROVED

Remarks:

Notes: No plans or truss docs in permit box and missing windows and doors

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 5/20/2024
Completed Date/Time: 5/20/2024
Inspector: James T Hall
Result: DISAPPROVED

Remarks:

Notes:

Missing windows and doors and missing correct flashing on windowsPorch post not installed at timeMissing nail guard at top plate on wire to left of panel in garageNail 2 & 3 ply trusses in throughout house per truss docsMissing nails in roof truss hangers in garageMissing air barriers under knee walls in garageReplace short nails in hangers in garage near split of the

doorsMissing 3 nails at joists on ledgers in garage floor joistNeed 2 king studs on each side of lvl beam in back of garageMissing air barriers under stairs on back wallsNeed 3' head of water on

drain line test in laundry roomDouble studs at drain line in laundry room or use stud guardsAnchor all interior load bearing walls per codeMissing hurricane straps on trusses at stairsMissing hurricane straps on 2 ply truss at bottom of stairs each endReplace all short nails in hangers for roof trusses with correct size nailsAnchor all toilet flanges per codeNeed 4 king

studs and 4 jack studs each end of back door stop inspection

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 5/22/2024

Completed Date/Time:

Inspector: Steven Gazlay

Result: Remarks: Notes: