Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

## SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: GALT Applicant:	
Address: 72 Rush (n Date Evaluated: 1-3-23	
Proposed Facility: SFD Design Flow (.1949): 480 Property S	ize:
Location of Site: Property Recorded:	
Water Supply: ☐ Public☐ Individual ☐ Well ☐ Spring	Other
Evaluation Method: ✓ Auger Boring ☐ Pit ☐ Cut	
Type of Wastewater: Sewage Industrial Process Mixed	l


P R O F I L E	.1940 Landscape Position/ Slope %			DRPHOLOGY 1941	OTHER PROFILE FACTORS				
		Horizon Depth (In.)	.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1,3	L	0-13	45	F/NSP/NXP	>48"	>48"		_	PS. 4
	L 5-7%	13-48	Sci	Filssplaxe					-
				. ,					
									00
2	L	0-16	45	fo/NSp/MA	248"	>48"			PS. 4
	5-7%	16-48	ser	Filssplssel					

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948):
Available Space (.1945)			Evaluated By: MREHS
System Type(s)			Others Present:
Site LTAR	.4	- 4	A. (.

COMMENTS: \_\_\_\_

ABK-ANGULAR BLOCKY

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	1	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		
STRUCTURE SG-SINGLE GRAIN M- MASSIVE		MINERALOGY SLIGHTLY EXPANSIVE			
CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY		EXPANSIVE			



Rush