

Harnett County Department of Public Health

SR, 1547 Carson Gregory

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 44 Junius Ct, Angier, 27501
 SUBDIVISION Ev:15 Place LOT # 1
 ISSUED TO: Cumberland Homes INC
 NEW REPAIR EXPANSION
 Type of Structure: SFD 30'x54'
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit valid for: Five years No expiration
 Permit conditions: _____

Authorized State Agent: James E. Manshart Date: 12-14-23 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Homes INC PROPERTY LOCATION: 44 Junius Ct, Angier, 27501
 SUBDIVISION Ev:15 Place LOT # 1
 Facility Type: SFD 50'x54' New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable 50% Reduction System (Repair))

Installation Requirements/Conditions
 Septic Tank Size 1,000 gallons
 Pump Tank Size _____ gallons
 Number of trenches 4
 Exact length of each trench 66 feet
 Trenches shall be installed on contour at a max
 Maximum Trench Depth of: 18-24 inches
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: EASEMENTS TO BE MARKED PRIOR TO INSTALLATION _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manshart Date: 12-14-23
 Construction Authorization Expiration Date: 12-14-28

Application # SFD 2310-0039


Harnett County Department of Public Health Site Sketch

Property Location: 44 Junius Ct, Angier, 27501, SR 1547 Carson Gregory Rd

Issued To: Cumberland Home Inc Subdivision Greets Place Lot # 1

Authorized State Agent: James E. Manhart Date: 12-14-23

*All Easements to be marked Paint to INSTALL.



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.